



BOX
CDR WB 00-1118-12

LID
CDR WC 00-1118-02 GS

*COORDINATE LOCATION & DEPTH WITH ENGINEER IN FIELD

**TERMINATE CLEAN-OUTS AT GRADE FOR IMPROVED PROPERTIES AND 3'-0" ABOVE GRADE FOR IMPROVED PROPERTIES

ALL PIPES AND FITTINGS SHALL BE GREEN 6" MIN. SDR 35

SERVICE LATERALS WITH RISERS 2011

ENGINEERING STANDARDS 2011

REVISIONS		ENGINEERING DEPARTMENT CITY OF POMPANO BEACH	SERVICE LATERALS
BY	DATE		
S.S.	JUNE 2005		
T.W.	11-2007		
SCALE: N.T.S.		DATE: JUNE 1996	DWG. NO.
		200-1	