



NOTES:

1. BALL VALVE, PIPING, ETC., TO MATCH AIR RELEASE VALVE DIAMETER.
2. MISCELLANEOUS ARV ACCESSORIES SHALL BE SELF-CONTAINED AUTOMATIC PROCESS VALVES.
3. RAMNEK AT ALL RISER JOINTS WITH GROUT ON INSIDE AND OUTSIDE AT ALL RISER JOINTS.
4. MANHOLE FABRICATION SHALL BE IN ACCORDANCE WITH ASTM C-478, LATEST STANDARD.
5. COAT INSIDE AND OUTSIDE OF MANHOLE WITH PROTECTIVE COATINGS.
6. THE CHIMNEY AREA SHALL BE A MINIMUM OF 4" AND A MAXIMUM OF 12" IN HEIGHT. A MINIMUM OF 3 COURSES OF BRICK SHALL BE INSTALLED. SET IN 2 STRIPS OF SEALANT/ADHESIVE COMPOUND ON EACH SEALING FACE.
7. SET MANHOLE FRAME ON 2 STRIPS OF SEALANT PLUS A BED OF PORTLAND CEMENT AND SILICA SAND. BRING MORTAR UP OVER FRAME.

SEWAGE AIR RELEASE VALVE 2011

ENGINEERING STANDARDS 2011

REVISIONS		ENGINEERING DEPARTMENT CITY OF POMPANO BEACH	SEWAGE AIR RELEASE VALVE	
BY	DATE			
S.S.	JUNE 2005		DATE: JUNE 1996	
			DWG. NO.	
		SCALE: N.T.S.	210-1	