

USE MEGALUGS AT ALL PIPE JOINTS

FLUSH WITH GRADE
 CAST IRON VALVE BOX LID
 (SEE SPECIFICATIONS)

6" MIN.
 12" MAX.

ADJUSTABLE SCREW TYPE C.I.
 VALVE BOX UPPER SECTIONS

CAST IRON VALVE BOX
 LOWER SECTION CENTERED
 OVER OPERATING NUT.

SNAP ON LOCKING EXTENSION
 ROD W/2" OPERATING NUT TO
 12" MIN. 18" MAX. BELOW GRADE
 IF VALVE OPERATING NUT IS
 OVER 3'-0" DEEP.

VALVE SIZE AND ENDS
 AS SPECIFIED

GATE OR PLUG VALVE SETTING

ALL D.I.P. TO BE PAINTED
 BLUE ON TOP HALF OF PIPE.

ENGINEERING STANDARDS

REVISIONS		ENGINEERING DEPARTMENT CITY OF POMPANO BEACH	GATE OR PLUG VALVE SETTINGS	
BY	DATE			
S.S.	APRIL 2005		APPROVED BY:	DATE: JUNE 1996
T.W.	11-2007		CITY ENGINEER	DWG. NO.
SCALE: N.T.S.		103-1		