



\*\* ALL WATER METERS ARE INSTALLED PERPENDICULAR TO WATER MAIN.

SINGLE SERVICE

DOUBLE SERVICE

- (A) 1" TAPPING SADDLE CC THREAD FORD
- (B) 1" CORPORATION STOP FORD TYPE F1000-4 CC THREADS
- (C) 1" POLYETHYLENE SOLID BLUE CTS SDR 18 (200 PSI)
- (D) 1 1/2" SCH. 40 FOR 1" SERVICE  
2 1/2" SCH. 40 FOR 2" SERVICE  
PAINTED BLUE

- (A) 1" TAPPING SADDLE (2) FORD FC-202 OR EQUAL.
- (B) 1" CORPORATION STOP (2) FORD TYPE F1000
- (C) 1" POLYETHYLENE SOLID BLUE C.T.S. (2)
- (D) 2 1/2" SCH. 40 FOR 1" SERVICE  
6" SCH. 40 FOR 2" SERVICE  
PAINTED BLUE

**TYPICAL 1" WATER SERVICE 2011**

**ENGINEERING STANDARDS - 2011**

REVISIONS		ENGINEERING DEPARTMENT CITY OF POMPANO BEACH	TYPICAL WATER SERVICE	
BY	DATE			
K.J.B.	08.23.04		SCALE: N.T.S.	DATE: JUNE 1996
S.S.	04-2005			DWG. NO.
T.W.	11-2007			107-1
S.S.	05-2011			