



SINGLE SERVICE

DOUBLE SERVICE

- (A) 1" TAPPING SADDLE CC THREAD
FORD FC-202 OR EQUAL.
- (B) 1" CORPORATION STOP
FORD TYPE F1000
- (C) 1" POLYETHYLENE SOLID BLUE CTS
SDR 18 (200 PSI)
- (D) 1 1/2" SCH. 40 FOR 1" SERVICE
2 1/2" SCH. 40 FOR 2" SERVICE

- (A) 1" TAPPING SADDLE (2)
FORD FC-202 OR EQUAL.
- (B) 1" CORPORATION STOP (2)
FORD TYPE F1000
- (C) 1" POLYETHYLENE SOLID BLUE C.T.S. (2)
- (D) 2 1/2" SCH. 40 FOR 1" SERVICE
6" SCH. 40 FOR 2" SERVICE

TYPICAL 1" WATER SERVICE

USE MEGALUGS AT ALL PIPE JOINTS

ALL D.I.P. TO BE PAINTED
BLUE ON TOP HALF OF PIPE.

ENGINEERING STANDARDS

REVISIONS		ENGINEERING DEPARTMENT CITY OF POMPANO BEACH	TYPICAL WATER SERVICE	
BY	DATE			
S.S.	4/19/00		APPROVED BY:	DATE: JUNE 1996
K.J.B.	08.23.04		CITY ENGINEER	DWG. NO.
S.S.	APRIL 2005			107-1
T.W.	11-2007	SCALE: N.T.S.		