



City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060



March 8, 2011

ADDENDUM #1, BID H-26-11
MODIFICATION OF LIFT STATION 102

To All Bidders,

Please review the following requests for information, and answers provided by the City's consultant:

Q1: What louver is going with chain link fence?

A1: The proposed vinyl coated chain link fence will include privacy slats to provide visual screening of the lift station area. The privacy slats should be Plastic Vertical Tubing (PVT) style of green PVC construction.

Q2: After the demolition of the existing slab, you can form a new slab covering the entire area and it is unclear whether to put a new slab to wetwell and then to take another to cover entire area 11.5' x19.5'. We need to know if installing a single slab of 11.5'x19.5' enough? Clarify this please.

A2: The project includes the installation of new precast top slabs for the existing wetwell under Bid Item #15 and for the existing valve vault under Bid Item #17. The project includes the installation of a new housekeeping slab (11.5'x19.5') which is to be cast in place around the existing wetwell and valve vault under Bid Item #35. The configuration of the housekeeping slab will be sufficient and matches the dimensions of the existing housekeeping slab. The detail drawings for the top slabs are included on Sheet 4 of the plans.

Q3: Where is the outgoing force main located relative to the public right of way for Andrews Avenue?

A3: The outgoing force main from Lift Station #102 is a 6-inch diameter pipe which is routed west within a 30 feet wide easement toward NE 15th Avenue. The outgoing force main from Lift Station #102 is not located within the right of way for North Andrews Avenue.

The City will receive partial reimbursement from FDOT for this project, and FDOT requires that the E-Verify system be used for all persons performing work on this contract. The City will require the contractor awarded Bid H-26-11 to complete the enclosed form agreeing to use the U.S. Department of Homeland Security's E-Verify system.

The remainder of the Bid is unchanged at this time. The deadline for receipt of sealed bids remains 2:00 p.m., March 18, 2011, in the Purchasing office, 1190 N.E. 3rd Avenue, Building C, Pompano Beach, Florida, 33060.

Acknowledge receipt of this Addendum in the area provided on the Bid Proposal Form, page 14.

Very truly yours,

A handwritten signature in black ink, appearing to read "Leeta Hardin". The signature is fluid and cursive, with a horizontal line above the name.

Leeta Hardin
General Services Director

enclosure

cc: planholders/prebid list
website
file

E-VERIFY

Contract No: _____

Financial Project No(s): _____

Project Description: _____

Vendor/Consultant acknowledges and agrees to the following:

Vendor/Consultant shall utilize the U.S. Department of Homeland Security's E-Verify system, in accordance with the terms governing use of the system, to confirm the employment eligibility of;

1. all persons employed by the Vendor/Consultant during the term of the Contract to perform employment duties within Florida; and
2. all persons, including subcontractors, assigned by the Vendor/Consultant to perform work pursuant to the contract with the Department.

Company/Firm: _____

Authorized Signature: _____

Title: _____

Date: _____