



**City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060**

October 17, 2011

**ADDENDUM #1, BID H-58-11
FLUORIDE METERING SKID**

To Whom It May Concern,

The deadline for receipt of sealed is extended to 2:00 p.m., Tuesday, October 25, 2011, in the Purchasing office, 1190 N.E. 3rd Avenue, Building C, Pompano Beach, Florida, 33060.

Please review the following requests for information, and answers provided by the City:

1. Question, Specification Section 1.3.A.1: Our representative in Florida, AMJ Solares, is trained, fully capable and authorized to make repairs to all components of the chemical feed system. Is this acceptable?

Answer: Yes, this is acceptable.

2. Question, Specification Section 1.3.A.3.b: Our standard skid material is a blend of Polypropylene and High Density Polyethylene, which is Black and UV Protected. This is a proven material which provides a good combination of rigidity and impact resistance. Is this acceptable?

Answer: Yes, this is acceptable.

3. Question, Specification Section 1.3.A.6: We would like to include a proposal for professional maintenance of the equipment by a factory trained technician. who shall be a regular employee of our authorized representative, AMJ Solares. Is this acceptable?

Answer: Yes, this is acceptable.

4. Question, Specification Section 1.3.A.7: We request that ProMinent be named via addendum as an approved equal.

Answer: Yes, ProMinent may be considered equivalent.

5. Question, Specification Sections 1.4.D and 1.5.C.3.b: Same question as in 1.3.A.6

Answer: Yes, this is acceptable.

6. Question, Specification Sections 2.2.A.1 and 2.2.A.2: As requested above, would a blend of Polypropylene and High Density Polyethylene be acceptable?

Answer: Yes, this is acceptable.

7. Question, Specification Section 2.2 B: The City may wish to consider including a requirement for ULS08 rating on the Terminal Junction Box to ensure proper design and manufacturing.

Answer: The City will not change the specification for this.

8. Question, Specification Section 3.3.2.A: Is inspection and testing by a qualified manufacturer's representative acceptable?

Answer: Yes, this is acceptable.

9. Question, Specification Section 3.3.A.1.a: We cannot deliver the equipment with our own vehicle. We propose to use a common carrier with air ride suspension, with insurance provided for the full value of the equipment. Is this acceptable?

Answer: Yes, this is acceptable.

The remainder of the solicitation is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on Page 28 of the bid.

Very truly yours,



Leeta Hardin
General Services Director

cc: website
file