



City of Pompano Beach, Purchasing Division
1190 N.E. 3rd Avenue, Building C
Pompano Beach, Florida, 33060
954-786-4098 954-786-4168

ADDENDUM #1, QUOTATION #Q-12-011T
“DEMOLITION OF UNSAFE STRUCTURES”

February 2, 2012

To All Bidders,

Please review the following requests for information, and answer provided by City staff:


Q1: Should pool be removed at the property located at 1581 N.E. 48th Street,
Pompano Beach, Fl 33064-5720

A1: No. In ground pool must be punctured, emptied and filled with clean fill.
Sod is to be installed on all areas affected by demolition.

Any other questions call Sal Pravata, Unsafe Structures Inspector 954-786-4525

The remainder of the Quote is unchanged at this time. Acknowledge receipt of this Addendum in the area provided on the signature page.

Thank you



Tammy R. Thompkins